Town of Leland
Growing our future. Nourishing our roots.

102 Town Hall Drive - Leland, North Carolina 28451
(910) 371-0148 - Fax (910) 371-1073

NOTICE OF DISCHARGE OF UNTREATED WASTEWATER

On September 2, 2016, the Town of Leland Utilities had a discharge of untreated wastewater from a manhole of the 8" gravity sewer system located in front of 1352 Grandiflora Drive in the Magnolia Greens Subdivision in Leland, North Carolina. The amount of the spill was approximately 1,650 gallons. The discharge flowed from the manhole lid to the street stormwater collection system. Town personnel responded immediately to the overflow and followed all protocol in evaluating and determining the cause. No blockages, broken pipes, or faulty equipment were discovered. The discharge is believed to have been caused by increased volume in the downstream transmission line due to heavy rains from Tropical Storm Hermine resulting in increased head pressure that the Town's throttled-back pumps could not overcome. The Town of Leland shares the transmission line that runs to the Brunswick County NE Sewer Plant with other entities and the system has a finite capacity that it can accommodate. Crews continued to monitor the sewer spill and reported it to the DENR office. Please contact Jimmy Strickland at 910-332-4651 with any questions concerning this notice. This notice is required by NC General Statutes Article 21 Chapter 143.215.C.

END

Brenda Bozeman
Mayor

Pat Batleman
Mayor Pro Tem

Michael Callahan
Councilmember

Bob Campbell
Councilmember

Bob Corriston
Councilmember

David A. Hollis
Town Manager