



Town of Leland

Public Utilities Department

102 Town Hall Drive
Leland, NC 28451
Phone: (910) 371-0148
Fax: (910) 383-3219

2010-2011 Wastewater Collection System Annual Report

Permittee: Town of Leland
102 Town Hall Drive
Leland, NC 28451

Responsible person: Jimmy Strickland
Public Utilities Director/ORC
102 Town Hall Drive
Leland, NC 28451
Phone :(910)-332-4651
Fax :(910)-383-3219

Permit No.: WPCS00333 **Name: Town Of Leland**

The Town of Leland has over 3,700 sewer customers, 41 miles of 12", 10" and 8" gravity sewer lines, 5 miles of force mains, and twenty-four lift stations in the collection system. The wastewater collected from the system is treated at the Northeast Treatment Plant operated by Brunswick County.

The Public Utilities Department is responsible for the daily operation and maintenance of the collection system. System Maintenance includes cleaning 10% of the system and daily monitoring of the lift stations.

The Town of Leland Public Utilities Department had 2 reportable sewer spills in the past year, 2010. On February 23, 2010 an overflow at a manhole on Kobus Court spilled 1,000 gallons of untreated wastewater into a nearby ditch and from there into Jacky's Creek. The overflow was caused by an electrical problem at Lift Station # 1, which is located in the Magnolia Greens neighborhood. On September 27, 2010 after several inches of rain there was a discharge of 2,500 gallons wastewater from a manhole located at the intersection of Pine Harvest Drive and Pemberton. The wastewater entered a nearby retention pond. The incidents listed above have all been address and corrected.

A public notice has been placed in local newspapers informing the public that copies of the annual report for the collection system are available upon request at the Town of Leland's Public Utilities Department. The report is also available on the town's website. The report is also being sent to the State of North Carolina by mail in January 2011

I certify under penalty of law that this report is complete and accurate to the best of my knowledge. I further certify that this report has been made available to the users or customers of the named system and that those users have been notified of its availability.

Bill Farris, Manager, Town of Leland

Signature of Permittee : *Bill Farris*

Date: *1.14.11*