



NOTES:

1. THE CENTER PORTION OF THE CURB RAMP SHALL MATCH THE WIDTH OF THE SIDEWALK.
2. THE CENTER PORTION OF THE CURB RAMP SHALL BE AT LEAST 48" WIDE.
3. MAINTAIN POSITIVE STORMWATER FLOW IN THE FLOW LINE OF THE GUTTER.
4. RAMP LENGTH SHALL BE 2' MIN.
5. FILLED EXPANSION JOINTS ARE REQUIRED BETWEEN NEW CONCRETE AND EXISTING CONCRETE AND WHERE CONCRETE CHANGES THE ANGLE OF CONSTRUCTION.
6. RAMPS MUST MEET CURRENT ADA ACCESSIBILITY STANDARDS.

| | | |
|----------------------|---|--|
| SECTION: STREETS | <p>TYPICAL CURB RAMP ON STREET WITH VERTICAL CURB AND GUTTER (HARD RETURN STYLE)</p> | <p>PUBLIC SERVICES DEPARTMENT</p> |
| DATE: 2021 | |  <p>Town of Leland</p> |
| DRAWN BY: JWP | | <p> </p> |
| CHECKED BY: TOWN PSD | | <p>DETAIL NO. ST - 08</p> |
| SCALE: NOT TO SCALE | | |