

CURB RAMP NOTES

1. ALL CURB RAMPS SHALL BE INSTALLED IN ACCORDANCE WITH THE AMERICANS WITH DISABILITIES ACT (ADA) LATEST EDITION.
2. ALL CONCRETE SHALL BE CLASS A WITH A 28 DAY BREAK OF AT LEAST 3,000 PSI.
3. THE WALKING SURFACE OF THE RAMP SHALL HAVE A SLIP RESISTANT FINISH.
4. THE SLOPE OF THE CURB RAMP SHALL NOT EXCEED A 12:1 RATIO.
5. THE DETECTABLE WARNING DEVICE OF THE CURB RAMP SHALL BE RED CONTRAST AND MUST BE IN COMPLIANCE WITH ADA REQUIREMENTS.
6. A FULL DEPTH EXPANSION JOINT SHALL BE INSTALLED WHERE THE CONCRETE CURB RAMP JOINS THE CURB AND GUTTER AND THE CONCRETE CURB RAMP ABUTS EXISTING CONCRETE SIDEWALK.
7. ALL CURB RAMPS SHALL BE THE SAME WIDTH AS THE ADJOINING SIDEWALK OR 48" WIDE IF THE SIDEWALK IS LESS THAN 48" WIDE.
8. COORDINATE THE CURB RAMP AND THE PEDESTRIAN CROSSWALK MARKINGS SO A 4' X4' CLEAR SPACE AT THE BASE OF THE CURB RAMP WILL FALL COMPLETELY WITHIN THE PEDESTRIAN CROSSWALK LINES.

SECTION: STREETS	CURB RAMP NOTES	PUBLIC SERVICES DEPARTMENT
DATE: 2021		
DRAWN BY: JWP		
CHECKED BY: TOWN PSD		
SCALE: NOT TO SCALE		