


TABLE 1

COVER REQUIREMENTS FOR PIPE IN R.O.W. FROM INVERT TO SUBGRADE	
PIPE SIZE (in)	COVER DEPTH (ft)
15	2.5
18	2.75
24	3.3
30	3.6
36	4.5
42	5.0
48	5.5
54	6.0
60	6.5

NOTES:

1. HAUNCH COMPACTED IN ACCORDANCE WITH ASTM D2321
2. INITIAL BACKFILL COMPACTED TO 100% DENSITY
3. INSTALL PER HDPE PIPE MANUFACTURER'S RECOMMENDATIONS

SECTION: STORMWATER	BEDDING FOR HDPE PIPE	PUBLIC SERVICES DEPARTMENT
DATE: 2021		
DRAWN BY: JWP		
CHECKED BY: TOWN PSD		DETAIL NO. SW - 04
SCALE: NOT TO SCALE		