


NOTES

1. THE CENTER PORTION OF THE CURB RAMP SHALL MATCH THE WIDTH OF THE SIDEWALK.
2. THE CENTER PORTION OF THE CURB RAMP SHALL BE AT LEAST 48" WIDE.
3. MAINTAIN POSITIVE STORMWATER FLOW IN FLOWLINE OF THE GUTTER
4. RAMP LENGTH SHALL BE 2' MIN.
5. FILLED EXPANSION JOINTS ARE REQUIRED BETWEEN NEW CONCRETE AND EXISTING CONCRETE AND WHERE CONCRETE CHANGES THE ANGLE OF CONSTRUCTION.
6. RAMPS MUST MEET CURRENT ADA ACCESSIBILITY STANDARDS.

SECTION: STREETS	TYPICAL CURB RAMP ON STREET WITH MODIFIED VALLEY (ROLL OVER) CURB AND GUTTER (WING STYLE)	PUBLIC SERVICES DEPARTMENT
DATE: 2021		
DRAWN BY: JWP		
CHECKED BY: TOWN PSD		
SCALE: NOT TO SCALE		