


COVER REQUIREMENTS FOR PIPE IN R.O.W. FROM INVERT TO SUBGRADE	
PIPE SIZE (in)	COVER DEPTH (ft)
15	2.5
18	2.75
24	3.3
30	3.6
36	4.5
42	5.0
48	5.5
54	6.0
60	6.5

SECTION: STORMWATER	<b>BEDDING FOR REINFORCED CONCRETE PIPE</b>	PUBLIC SERVICES DEPARTMENT
DATE: 2021		
DRAWN BY: JWP		
CHECKED BY: TOWN PSD		
SCALE: NOT TO SCALE		